



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

PIDILITE MEA CHEMICALS LLC

Dubai Investment Park 2, Dubai UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2023 AL SA'FAT DUBAI GREEN BUILDING SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

ENG. MAJED AL SHAMSI

Certification and Quality Control of Products Section's Acting Manager
Dubai Central Laboratory Department-Dubai Municipality



Certificate No: CL18020594 Rev. 01
Valid Until: 13/06/2025



Current Issue Date: 15/08/2024
Original Issue Date: 14/06/2018



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



DUBAI CENTRAL LABORATORY DEPARTMENT DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020594-REVISION 01

Certificate Issued To:	PIDILITE MEA CHEMICALS LLC Dubai Investment Park 2, Dubai, UAE
Applicable Standard Specification:	2023 Al Sa'fat Dubai Green Building System-2nd edition - clauses [404.01] and/or [404.02], [304.01], [304.04] [304.07], [701.04] and related clauses in 2021- Dubai Building Code.
Applicable Specific Rules:	DM-DCLD-RD-DP21-2180-(IC): Certification of Low Emitting Materials as per 2023 Al Sa'fat Dubai Green Building System-2nd edition.

S/N	Product Description	Brand Name	Product Details
1.	Two Pack reactive Performance Coatings for specific end use such as floor (Category 10)	Dr. Fixit Unilastic 811	Water Base Coating for Interior and Exterior Application VOC (Al Sa'fat DGBS limit is Max. 140 g/L) Formaldehyde \leq 10 mg/kg
		Dr. Fixit Fastflex	
		Dr. Fixit Unicem 3.1	
		Dr. Fixit Unicem 3.1 White	
		Ikan CWP	
		Ikan FCWP	
		ROK Polyurethane Topcoat	Solvent Base Coating for Interior and Exterior Application VOC (Al Sa'fat DGBS limit is Max. 500 g/L) SRI (Result of sample tested is \geq 78) White Color (See Note 4)
		ROK Aquabond	
		ROKCOAT EPSF	
		ROK Prime EPSF	
		ROK Floor EPSL	
		ROK Screed EP	

DUBAI CENTRAL LABORATORY DEPARTMENT DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020594-REVISION 01

		Stauf Floorfix VEP93	
		Dr. Fixit Epoxy Putty	
		Roff Grout EP	
		ROK Polyurethane High Build Coating	
2.	One-Pack Performance Coatings (Category 9)	Dr. Fixit Uniproof 5000	<p style="text-align: center;">Water Base Coating for Interior and Exterior Application</p> <p style="text-align: center;">VOC (Al Sa'fat DGBS limit is Max. 140 g/L) Formaldehyde \leq 10 mg/kg</p> <p style="text-align: center;">SRI (Result of sample tested is \geq78) White Color (<i>See Note 4</i>)</p>
		Dr. Fixit Polyplus CD Admix	
		Dr. Fixit Polyplus CP	
		Dr. Fixit Uniproof 4000	
		Dr. Fixit Unithane HB	
		Fevicol AC Duct King Lag coating AF 5590	
		Fevicol AC Duct King Lag coating E84	
		Fevicol Microprotect	
		Fevicol Weatherprotekt	
		Dr. Fixit Raincoat Ultraflex	
3.	Binding Primers (Category 8)	Dr. Fixit Unibond PVA 201	<p style="text-align: center;">Water Base Coating for Interior and Exterior Application</p> <p style="text-align: center;">VOC (Al Sa'fat DGBS limit is Max. 30 g/L) Formaldehyde \leq 10 mg/kg</p>
		Dr. Fixit Unibond SBR 202	
		ROK Bond SBR	
		ROK ASP	
		ROK DSP	
		Stauf Floorfix D 53	
		Stauf Floorfix D 63	
		IKAN POLYCRETE	

DUBAI CENTRAL LABORATORY DEPARTMENT DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020594-REVISION 01

4.	Ceramic Tile Adhesive <i>(See Note 5)</i>	Roff Tile 601	Architectural Application VOC (Al Sa'fat DGBS limit is Max. 65 g/L)
		Roff Tile C1	
		Roff Tile C2	
		Roff Grout GP	
		Rok Floor 25	
		Dr. Fixit Unigrout 505	
		Dr. Fixit Unigrout 500	
		Dr. Fixit Micro Concrete	
		Dr. Fixit Modern Tile Glue	
		IKAN Tilobond	
		IKAN Ecobond	
		IKAN Progrout SPF	
		IKAN Flexbond	
		IKAN Probond	
		Stauf Floorfix FS	
		Floorfix SL-24	
		Morcemcolor Universal Grout	
		Morcemcolor Plus Flexible	
Pegoland Uno			
Pegoland Uno Plus			
Pegoland Dos			
Pegoland Dos Plus			
Pegoland Flex			
Pegoland Classic			
5	Carpet Pad Adhesive	Fevicol Floorfix Xpress	Architectural Application VOC (Al Sa'fat DGBS limit is Max. 50 g/L)
		Fevicol Floorfix Super TAC	
		Fevicol Floorfix D3 +	
		Fevicol floorfix 333	
6	Multi-Purpose Construction Adhesive	IKAN Propoxy 2K Epoxy & Grout	Architectural Application VOC (Al Sa'fat DGBS limit is Max. 70 g/L)

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020594-REVISION 01**

7	Adhesive for Fiberglass Substrate Application	Fevicol AC Ductking Ecofresh	Substrata specific applications VOC (Al Sa'fat DGBS limit is Max. 80 g/L)
8	SEALANTS	Fevicol Ac Duct King Duct Sealant 3278	Sealants for Architectural Applications VOC (Al Sa'fat DGBS limit is Max < 250 g/L)

NOTE 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCLD Conformity Mark.

NOTE 3: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).

NOTE4: The above SRI value is just for information. The user (owner, contractor and/or consultant) shall be fully responsible for ensuring that the correct SRI value is followed according to the requirements of the applicable clause in the standard specification. The acceptance limit shall be as per these values for each application of the product.

NOTE 5: Produced by PIDILITEPUMA MEA CHEMICALS LLC, an outsourced factory by PIDILITE MEA CHEMICALS LLC.

Original Issue Date : 14 June 2018

Current Issue Date : 15 August 2024

Valid Until : 13 June 2025

ENG. MAJED AL SHAMSI

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION'S ACTING MANAGER